



SPRINKLER SYSTEM MAINTENANCE

Minimum requirements for the periodic inspection, testing, and maintenance of fire protection systems should be part of the regular scheduled preventive maintenance program for any facility equipped with a sprinkler system. The accumulation of sawdust and wood bi-products in woodworking operations can create conditions that result in the failure of protective systems.

The National Fire Protection Association has specifically addressed several areas that need to be included in the routine maintenance and clean-up operations for any woodworker. The areas that need to be addressed that relate to sawdust and wood products include maintenance of fire protection systems.

The general responsibility for the owner or occupant of a building regarding fire protection systems is to provide periodic inspection, testing and maintenance of the equipment. The maintenance for a woodworking operation includes the cleaning off of the accumulation of sawdust on the sprinkler system piping, heads, and alarm devices. Cleaning should be by brushing or vacuum method and not by blowing off the accumulation with compressed air nozzles or other devices.

Including periodic inspection and cleaning of fire protection systems will also prevent the buildup of sawdust on building systems. The buildup of sawdust and wood products can lead to an unusual fire exposure and can inhibit the effectiveness of the fire detection and suppression systems should a fire occur.

Below are the NFPA guidelines for Sprinkler System Inspection, Testing, & Maintenance.

FREQUENCY	SYSTEM	ACTIVITY	ITEM	PURPOSE
DAILY	DPV	Inspection	Valve Enclosure	Assure adequate heat is maintained
WEEKLY	All	Inspection	Control Valves (not locked or supervised)	Assure valve is open; no leakage
	All	Inspection	Sprinkler Heads	Check for blockage, damage
	DPV	Inspection	Pressure Gauges (no air press. monitor)	Assure normal pressures are maintained
	DPV	Inspection	Check Drip Drums for Condensation (during cold weather)	Assure water is not building up in low points
MONTHLY	All	Inspection	Fire Department Connections	Check accessibility; caps in place; no leakage
	All	Inspection	Control Valves (locked or supervised)	Assure valve is open & locked / supervised; no leakage
	DPV	Inspection	Pressure Gauges (with air press.monitor)	Assure normal pressures are maintained
	DPV	Inspection	External Inspection of Valve	Check for physical damage, leakage
	WPV	Inspection	Pressure Gauges	Assure normal pressures are maintained
QUARTERLY	All	Inspection	Alarm Devices	Check for physical damage
	All	Test	Flow Main Drain	Determine condition & volume of water supply; assure control valve is open
	All	Maintenance	Exercise Post Indicator Valves	Assure adequate mechanical operation of PIV and that valve is completely open
	DPV	Inspection	Dry Pipe Valve Priming Water Level	Assure priming water level is adequate

	DPV	Test	Waterflow Alarm Test - use of alarm by-pass valve	Assure adequate operation of audible alarm & transmission of signal to supervising company
	DPV	Test	Low Air Pressure Alarm Test	Assure adequate operation of alarm when air pressure drops significantly
	DPV	Test	Test Quick Opening Device (QOD)	Assure adequate operation of QOD
	WPV	Test	Waterflow Alarm Test - use of inspector's test connection	Assure adequate operation of audible alarm & transmission of signal to supervising company
SEMI-ANNUALLY	Deluge & Preaction	Test	Fire Detection System Test	Assure adequate operation of fire detection system signal which releases water into the branch lines
ANNUALLY	All	Inspection	Sprinkler Piping - External Inspection	Assure no leaks, damage, corrosion, or misalignment
	All	Inspection	Spare Sprinklers	Assure adequate spare number of each type
	All	Inspection	Hangars	Assure no loose or damaged hangars
	All	Maintenance	Lubricate OS&Y valve stems	Assure adequate operation of valve
	DPV	Test/Insp.	Partial Trip Test / Inspection of Valve Interior	Assure adequate operation of dry pipe valve
	WPV	Inspection	Inspect Building	Assure that no portion of piping is exposed to freezing temperatures
	WPV	Test	Test Freezing Point of Antifreeze Solution	Assure that solution will not accidentally freeze during cold weather
EVERY 3 YEARS	DPV	Test	Full Trip Test	Assure adequate operation of dry pipe valve, adequate operation of QOD (if any); & water reaches most remote point in system within 1 min.
EVERY 5 YEARS	All	Inspection	Alarm Valve & Check Valve - Internal Inspection	Assure adequate operation of valve
	All	Test	Test Representative Sample of Sprinkler Heads with Temperature Rating of Extra High or Greater	Assure adequate operation of heads
	All	Test	Gauges - Test of Replace	Assure accurate gauge readings
	DPV	Maintenance	Internal Pipe Examination (Note 1: First exam. may be performed 15 yrs. after system placed in service) (Note 2: Exam. must be performed immed. after evidence of foreign mat'l or obstruction found)	Assure adequate flow of water through all branch lines without obstruction
EVERY 50 YEARS	All	Test	Test Representative Sample of All Sprinkler Heads	Assure adequate operation of heads